

Test Report No. BTX 116402(1)/ZL/08

Date: 28 February 2008

Page 1 of 2

BUTE FABRICS LTD
4 BARONE ROAD,
ROTHESAY
ISLE OF BUTE
SCOTLAND
PA20 0DP
UNITED KINGDOM

Attention: S. M. Groarty

The following sample was submitted and identified by the client as:




<u>Sample Description:</u>	Bright red fabric (Rosslyn)
<u>Details of Sample:</u>	Fabric number: DS4533/CF750; Batch: Bright Red; PO:133006
<u>Date Sample(s) Received:</u>	20 February 2008
<u>Testing Period:</u>	Tested between 20/02/2008 and 28/02/2008
<u>Test(s) Requested:</u>	BS 5867: Part 2: 1980 Type B performance.
<u>Test Results:</u>	Detailed in Appendix A
<u>Comments/Conclusions:</u>	The sample tested meets the requirements of BS 5867: Part 2: 1980 Type B performance.

Signed for and on behalf of
 SGS United Kingdom Ltd



Zofia Lesik
 Assistant Technologist
 Softlines Department



This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document cannot be reproduced except in full, without prior approval of the Company.

Tests denoted with an * have been subcontracted to another UKAS Approved Laboratory. Tests marked [Non UKAS Accredited] in this Report/Certificate are not included in the UKAS Accredited Schedule for our Laboratory

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation

Appendix A: Test Results

Specification for curtains and drapes (BS 5867: Part 2: 1980)

Flammability requirements: Type B performance

Cleansing procedure:

The sample was tested after water soaking in accordance with BS 5651: 1978 clause 4.

Requirements: No part of any hole nor any part of the lowest boundary of any flame shall reach the upper edge or either vertical edge of any specimen, and there shall be no separation of flaming debris.

Results: These results may not apply to situations where there is restricted air supply or prolonged exposure to large sources of intense heat as in a conflagration.

<u>Flame application time : 15 s</u>	<u>Length</u>			<u>Width</u>		
	1	2	3	1	2	3
Flame reached an edge :	No	No	No	No	No	No
Hole reached an edge :	No	No	No	No	No	No
Flaming debris :	No	No	No	No	No	No

***** End of Report*****

This document is issued by the Company under its General Conditions of Service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only. This document cannot be reproduced except in full, without prior approval of the Company.

Tests denoted with an * have been subcontracted to another UKAS Approved Laboratory. Tests marked [Non UKAS Accredited] in this Report/Certificate are not included in the UKAS Accredited Schedule for our Laboratory

Opinions and interpretations expressed herein are outside the scope of UKAS Accreditation